

Name & contact details of local testing laboratory hidden to prevent fraudulent reproduction of this document.



SANAS Accredited Testing Laboratory
No. *Hidden*

**CERTIFICATE OF ANALYSES
GENERAL WATER QUALITY PARAMETERS**

Date received: 2014 - 06 - 06

Date completed: 2014 - 06 - 18

Project number: *Hidden*

Report number: *Hidden*

Order number: -

Client name: Nashakele Specialist Imports

Contact person: Mr. S. Bezuidenhout

Address: P.O. Box 50184 Ranjesfontein 1683

e-mail: shawnbez@nashakele.co.za

Telephone: 087 940 1590/1

Facsimile: 086 636 4289

Mobile: 082 467 4694

Analyses in mg/ℓ (Unless specified otherwise)	Method Identification	Sample Identification: Natural Pressure UF Filter	
		Untreated	Treated
Sample Number		8407	8408
Suspended Solids at 105°C *	WLAB004	21	2.4
Colour in PtCo Units *	WLAB006	91	34
Turbidity in N.T.U	WLAB005	17	1.0
Dissolved Organic Carbon as C *	WLAB060	12	7.4
Faecal Coliform Bacteria / 100 mℓ *	WLAB021	22	0
E. Coli / 100 mℓ *	WLAB021	22	0

* = Not SANAS Accredited

Tests marked "Not SANAS Accredited" in this report are not included in the SANAS Schedule of Accreditation for this Laboratory.

Hidden

Technical Signatory

The information contained in this report is relevant only to the sample/samples supplied to [redacted]. Any further use of the above information is not the responsibility of [redacted]. Except for the full report, part of this report may not be reproduced without written approval of [redacted]. Details of sample conducted by [redacted] according to [redacted]/Sampling Plan and Procedures/SOP are available on request.